

ERRATA SHEET

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
 SAN DIEGO REGION**

TENTATIVE ORDER No. R9-2015-0104

**MASTER RECYCLING PERMIT FOR THE VALLEY CENTER MUNICIPAL WATER
 DISTRICT WOODS VALLEY RANCH WATER RECLAMATION FACILITY,
 SAN DIEGO COUNTY**

The following revisions are proposed for Tentative Order No. R9-2015-0104. The changes are shown in the table below in underline/strikeout format to indicate added and removed language, respectively.

Errata No.	Section	Revision
1	IV.C.3	3. Turbidity measurement of the recycled water effluent from the disk filters the WVRWRF shall not exceed a daily average value of 2 Nephelometric Turbidity Units (NTU), shall not exceed 5 NTU more than 5 percent of the time during a 24-hour period, and shall not exceed 10 NTU at any time. <u>Turbidity measurement of the recycled water effluent from the membrane bioreactor shall not exceed 0.2 NTU more than 5 percent of the time within a 24-hour period and shall not exceed 0.5 NTU at any time.</u>
2	Attachment C, Information Sheet Section IV.B.3	3. Turbidity measurement of the recycled water effluent from the Facility <u>disk filters</u> shall not exceed a daily average value of 2 Nephelometric Turbidity Units (NTU), shall not exceed 5 NTU more than 5 percent of the time during a 24-hour period, and shall not exceed 10 NTU at any time. <u>Turbidity measurement of the recycled water effluent from the membrane bioreactor shall not exceed 0.2 NTU more than 5 percent of the time within a 24-hour period and shall not exceed 0.5 NTU at any time.</u>
3	Attachment D, Monitoring and Reporting Program	f. Effluent samples collected to determine turbidity (when required) shall be collected after the media filters. Effluent tertiary turbidity analyses shall be

	Section II.A.1, Table 1, footnote f.	<p>conducted continuously using a continuous monitoring and recording turbidity meter. Compliance with the daily average operating filter effluent turbidity limit of 2 NTU shall be determined using levels of recorded turbidity levels at a minimum of four-hour intervals over a 24-hour period. Compliance with the turbidity standard of not exceeding <u>0.2 NTU from the membrane bioreactor</u> or 5 NTU <u>from the disk filters</u> more than 5 percent of the time over a 24-hour period shall be determined using the levels of recorded turbidity taken at intervals of no more than 1.2 hours over a 24-hour period. Should the continuous turbidity meter and/or recorder fail, grab sampling at a minimum frequency of 1.2 hours may be substituted for a period of up to 24 hours. The Discharger shall report quarterly results of four-hour turbidity readings, average effluent turbidity (24-hours), 95 percentile effluent turbidity (24-hours), and daily maximum turbidity readings.</p>
--	--------------------------------------	---